

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

We routinely monitor for the presence of drinking water contaminants. Our water system recently violated drinking water standards. Although this was not an emergency, as our customers, you have a right to know what happened, what you should do, and what we are doing to correct this situation.

Pittsburg Co. RWD #14 Has Levels of Total Trihalomethanes (TTHMs) Above Drinking Water Standards

Testing results we received for the indicated time period(s) show that our system exceeds the standard, or maximum contaminant level (MCL), for total trihalomethanes (TTHM). The standard or MCL for TTHM is 0.080 mg/L. It is determined by averaging all the samples collected at each sampling location for the past 12 months. The following is the level of TTHM averaged at our system's location(s) :

<u>Twelve-month time period</u>	<u>Locational Running Annual Average with Sample Location</u>
October 2020 through September 2021	0.087 MG/L - 1045 RUSSELVILLE RD QUINTON, OK

What should I do? There is nothing you need to do unless you have a severely compromised immune system, have an infant or are elderly. These people may be at increased risk and should seek advice about drinking water from their health care providers.

What does this mean? This is not an emergency. If it had been, you would have been notified immediately. However, some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

CORRECTIVE ACTION: What happened? What is being done? When will the violation be resolved?
We purchase water and we started implementing more flushing to help resolve the problem.

For further information contact: ROY ENGLEMAN 918/429-1440

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by Pittsburg Co. RWD #14
PWS Number OK1020625 Case Number: CO 19-163 Date